



Henry W. Argo  
Fire Chief

## Fire Department Building / Construction Requirement's Check List

- |                                      |   |
|--------------------------------------|---|
| 1. Knox Key Box Required             | City Code 9-6                               |
| 2. Building/ Fire Safety Plans       | IFC 2018, LSC 2018,<br>Ga 120-3-3, IBC 2018 |
| 3. ADA                               | Ga 120-3-20                                 |
| 4. Sprinkler Plans                   | N.F.P.A 13                                  |
| 5. Fire Alarm Plans                  | N.F.P.A.72                                  |
| 6. Fire Department Radio Coverage    | IFC 2018 Section 510                        |
| 7. Fire Department Site Requirements | IFC 2018 Appendix C & D                     |

City of Palmetto Fire Rescue  
Post Office Box 570  
Palmetto, GA 30268 -0190  
770-463-2990 Office 770-463-2998 FAX